

Minnesota State Colleges and Universities



Normandale Community College

Request for Proposals for Architect/Engineering Services for
Parking Lots 1 & 2 Repair

Date: 10/26/2017

ADDENDUM #3

1. Questions submitted during Q& A period to campus:
 - a. How are the storm water infiltration systems working in lots 4 & 5?
ANS: The infiltration systems in all lots have been inspected and appear to be working with 1" or less of sediments as of Fall 2016. The "Labyrinth" (retention basin between the parking ramp and the science building) continues to hold more water than we expected. We don't know if it will be a solution for the project. The selected designer will need to assess and evaluate the basin to determine how it contributes to the overall storm water management system.

END OF ADDENDUM #3